



- NOTES:
1. VALVE OPERATING NUT EXTENSIONS ARE REQUIRED WHEN THE VALVE NUT IS MORE THAN THREE (3) FEET BELOW FINISHED GRADE. EXTENSIONS ARE TO BE A MINIMUM OF ONE (1) FOOT LONG. ONLY ONE EXTENSION TO BE USED PER VALVE.

<p><i>Gary M. Schimek</i></p> <p>APPROVED BY: GARY M. SCHIMEK NATURAL RESOURCES/STORMWATER ENGINEERING MANAGER</p>	 <p>City of Redmond WASHINGTON</p>	<p>STANDARD DETAILS</p> <p>STORMWATER GATE VALVE BOX AND EXTENSION</p>
<p>REVISION DATE: JULY 01, 2015</p>		<p>FILE NAME: SD612.DWG DETAIL NUMBER: 612</p>