


## SECTION

NTS




## VALVE ASSEMBLY DETAIL

NTS

NOTES:

1. COMBINATION AIR RELEASE AND VACUUM VALVE SHALL BE A 2 INCH SIZE MINIMUM - UNLESS OTHERWISE SHOWN ON THE CONSTRUCTION DRAWINGS.
2. FOR 1 INCH COMBINATION VALVE, INSTALL 2 INCH X 1 INCH REDUCER BETWEEN GATE VALVE AND UNION.
3. FILL METER BOX WITH SAWDUST AFTER TESTING AND INSPECTION.
4. INSTALL STANDARD MARKER POST IDENTIFYING VALVE LOCATION (NOT SHOWN).
5. SET METER BOX FLUSH WITH SIDEWALK OR CURB ELEVATION IF LOCATED IN LAWN AREA. SET METER BOX APPROXIMATELY 2 INCHES ABOVE FINISHED GRADE IF IN LANDSCAPED AREA.

| | | |
|---|---|---|
| Scott Thomasson<br>APPROVED BY: SCOTT THOMASSON<br>WATER/WASTEWATER ENGINEERING MANAGER | CityofRedmond WASHINGTON | STANDARD DETAILS<br>**COMBINATION AIR RELEASE AND VACUUM VALVE ASSEMBLY** |
| REVISION DATE: JULY 01, 2015 | | FILE NAME: SD706.DWG — DETAIL NUMBER: **706** |