



NOTES:

1. MINIMUM 54" TYPE 2 CB. LARGER MANHOLES REQUIRED FOR OUTLET PIPES GREATER THAN 12" OR MULTIPLE ORIFICE RESTRICTORS.
2. OUTLET CAPACITY: 50-YEAR DEVELOPED PEAK FLOW.
3. RESTRICTOR FABRICATED FROM ALUMINUM OR PVC PIPE.
4. FRAME AND LADDER OR STEPS OFFSET SO:
 - A. CLEANOUT GATE IS VISIBLE FROM TOP;
 - B. CLIMB-DOWN SPACE IS CLEAR OF RISER AND CLEANOUT GATE;
 - C. FRAME IS CLEAR OF CURB.
5. IF METAL OUTLET PIPE CONNECTS TO CEMENT CONCRETE PIPE, OUTLET PIPE TO HAVE SMOOTH O.D. EQUAL TO CONCRETE PIPE ID. LESS 1/4 IN.
6. PROVIDE AT LEAST TWO 3 X 0.090 GAUGE STAINLESS STEEL SUPPORT BRACKETS ANCHORED TO CONCRETE WALL WITH 5/8 IN STAINLESS STEEL EXPANSION BOLTS OR EMBEDDED SUPPORTS 2 IN INTO M/H WALL. MAX 3' OC.
7. LOCATE ELBOW RESTRICTOR(S) AS NECESSARY TO PROVIDE MIN CLEARANCE AS SHOWN.
8. ORIFICE SCREEN IS REQUIRED FOR ORIFICES LESS THAN 3" DIAMETER. RESTRICTOR PLATE FROM 12 GAUGE ALUMINUM OR PVC PIPE.
9. PIPE SIZES, INVERT ELEVATIONS, ORIFICE SIZE, OVERFLOW ELEVATIONS AND SLOPES PER PLANS.
10. OUTLET CAPACITY: NOT LESS THAN COMBINED INLETS.