



NOTES:

1. ELECTRICAL PERMIT REQUIRED IF WATER PUMP IS TO BE INSTALLED.
2. ENGINEERING DESIGN IS REQUIRED FOR CISTERNS GREATER THAN 60 GALLONS OR FOR BELOW GROUND SYSTEMS.
3. THERE SHALL BE NO CONNECTION BETWEEN RAIN HARVESTING SYSTEM AND POTABLE WATER SUPPLY.
4. THE OWNER IS RESPONSIBLE FOR ENSURING SAFE DISCHARGE OF OVERFLOWS WITHOUT CONCENTRATING FLOWS TO CAUSE EROSION OR FLOODING.

  
 APPROVED BY: GARY M. SCHIMEK  
 NATURAL RESOURCES/STORMWATER ENGINEERING MANAGER  
 REVISION DATE: JULY 01, 2015



STANDARD DETAILS	
<b>ROOF RAIN HARVESTING</b>	
FILE NAME: SD650.DWG	DETAIL NUMBER: <b>650</b>